

**IPPC Permit BJ 7336IL
Variation SP3736SJ**

**Aylesford Newsprint
Sludge Combustor Annual
Performance Report 2010**

Contents

1.	Introduction	3	
2.	Summary of Operator & PPC Permit Details	4	
3.	Plant Description	5	
4.	Overall Performance	6	
5.	Summary of Plant Monitoring	7	
6.	Summary of Emissions to Air	8	
7.	Emissions to Water	9	
8.	Summary of Plant Compliance	10	
9.	Summary of Plant Improvements	11	
10.	Summary of Information made available to the Public	12	
Appendix A			
Summary of Sludge Combustor Emissions (Oxides of Nitrogen, Carbon Monoxide, Particulates and TOC)			13
Appendix B			
Summary of 6-monthly sample Results & Compliance with WID Emission Limit Value (ELVs)			22
Appendix C			
Reporting of Performance Indicators for the period 1 January 2010 to 31 December 2010			25

1. Introduction

Aylesford Newsprint Limited (ANL) operates a sludge combustor at its Aylesford site and this combustor is subject to monitoring and reporting requirements dictated by the Waste Incineration Directive (WID) 2000/76/EC. Consequently, ANL has to submit to the Environment Agency an annual report summarising the performance of the sludge combustor for the previous year of operation, including an assessment of its emissions against Emission Limit Values (ELVs) detailed in the WID Directive.

This report constitutes ANL's Performance Summary report for its sludge combustor during 2010.

2. Summary of Operator & Environmental Permit Details

Table 2.1 below summarises the operator details (Aylesford Newsprint Limited) as well as contact details and the Environmental Permit which applies to the sludge combustor.

Table 2.1 Summary of Operator & Environmental Permit Details

Name of Company	Aylesford Newsprint Limited
Name of Plant	Sludge Combustor
Permit & Variation Number	Permit No.: BJ7336IL Variation No.: SP3736SJ
Address	Aylesford Newsprint Limited Newsprint House Bellingham Way Aylesford Kent ME20 7DL
Phone	01622 796000
Contact Name	Jenny Harbour
Position	Environmental Scientist
Description of Waste Burnt	Paper making waste (sludge and effluent treatment plant sludges)

3. Plant Description

The main purpose of the activities at the installation is the production of newsprint from recycled newspapers and magazines. A directly associated activity within the installation includes the treatment of aqueous effluent by means of an on-site biological effluent treatment plant. Both the paper production process and the on-site biological treatment of aqueous effluent give rise to sludge and these sludges are incinerated in an on-site sludge combustor.

Dewatered sludge is transferred to a storage silo from which it is fed to the sludge combustor. The combustion of sludge generates heat and this heat is recovered in an integral boiler system, which in turn generates steam. The steam generated is fed to a turbine for power generation.

The gases that are generated by the combustion process are cleaned and discharged through a dedicated stack. There are no releases to water or sewer from the air pollution abatement system.

The ash that is produced in the sludge combustor is collected and sent off-site for re-use or disposal.

4. Overall Performance

For 2010, the performance of ANL's sludge combustor is summarised in Table 4.1 below. The information has also been presented in the Environment Agency's proforma (See Appendix C).

The sludge combustor's performance was greatly enhanced in 2010 compared to 2009 due to the ability to take ash to Margett's Pit. However, during times when the building industry slowed, the volume of ash taken by our customers was reduced and the sludge combustor operation was closed when the ash silos became full.

Table 4.1 Overall Performance of ANL's Sludge Combustor (2010)

Performance Indicator	Value	Unit
Maximum sludge throughput Permitted	150,000	Tonnes per annum
Total waste incinerated	99,741	Tonnes
Type of waste incinerated	Paper making waste (sludge and effluent treatment plant sludges)	EWC Code 03 03 05
Total Plant Operating Hours	7109.57	Hours
Steam Generated	163,380	Tonnes
Natural gas	31.07	Kg / tonne of waste incinerated
Mass of bottom ash produced	11.74	Kg / tonne of waste incinerated
Mass of APC residues (fly ash) produced	651.94	Kg/ tonne of waste incinerated

Table 4.2 Fate of ash from sludge combustor

Type of Ash	Fate	%
Bottom Ash	Landfill	100%
APC Residues (fly ash)	Landfill	31%
	Recycled	69%

5. Summary of Plant Monitoring

To ensure efficient operation and to safeguard the environment, the following monitoring is undertaken.

Table 5.1 Details of Sludge Combustor Monitoring Performed

Pollutants measured	Continuously	Periodically
Particulates	✓	✓
Oxides of Nitrogen	✓	✓
Total Organic Carbon (TOC)	✓	✓
Carbon Monoxide	✓	✓
Hydrogen Chloride		✓
Hydrogen Fluoride		✓
Sulphur dioxide		✓
Mercury		✓
Cadmium and Thallium		✓
Arsenic, Lead, Chromium, Cobalt, Copper, Manganese, Nickel and Vanadium		✓
Dioxins/ Furans		✓

With regard to the pollutants that are monitored continuously, ANL keeps a log of any downtime associated with the individual continuous emission monitoring systems. Table 5.2 summarises the downtime and operational time for each Continuous Emissions Monitor (CEM).

Table 5.2 Sludge Combustor CEM Downtime (excluding calibration)

Continuous Emissions Monitor (CEM)	CEM Hours downtime	CEM % Operational time (based on total operating hours)
Oxides of Nitrogen (NO _x) meter	48 hours	99.32%
Carbon Monoxide (CO) meter	48 hours	99.32%
Particulates meter	48 hours	99.32%
Total Organic Carbon (TOC) meter	48 hours	99.32%

6. Summary of Emissions to Air

Oxides of Nitrogen (as NOx), Particulates and Carbon Monoxide (CO)

Emissions from the sludge combustor associated with NOx (NO & NO₂), particulates and CO are summarised in Charts A1 to A6 (Appendix A). It can be seen from these charts that the average half-hourly emissions of NOx, particulates and CO are all below the Emission Limit Values (ELVs), both for the ½ hourly and daily average ELV. Since the sludge combustor is classed as an existing incinerator in terms of the WID Directive, the limits specified in Table 6.1 below apply.

Table 6.1 WID Emission Limit Values for ANL's Sludge Combustor

Substance	Emission Limit Value (mg/m ³)	
	½ Hourly Average	Daily Average
Oxides of Nitrogen	400	200
Particulates	30	10
Carbon Monoxide	100	50
Total Organic Carbon (TOC)	20	10
Source: ANL's Environmental Permit BJ7336IL/ Variation SP3736SJ		

Total Organic Carbon

The sludge combustor is classed as an existing incinerator in terms of the WID Directive, the TOC limits specified in Table 6.1 apply.

Emissions from the sludge combustor associated with TOC are summarised in Charts A7 and A8 (Appendix A). It can be seen from these charts that the average half-hourly emissions of TOC are all below the Emission Limit Values (ELVs), both for the ½ hourly and daily average ELV.

The 6-monthly spot sample indicates that volatile organic compounds (VOCs) expressed as TOC did not breach this limit (see table B2, Appendix B).

VOCs, Gaseous chloride and fluorides, Dioxins, Furans, PCBs and Metals

Emissions from the sludge associated with VOCs, Gaseous chloride and fluorides, Dioxins, Furans, PCBs and metals are sampled every 6 months. Table B1 (Appendix B) summarises the sample results obtained for 2010 whilst Table B2 (Appendix B) summarises the WID Emission Limit Values. From Table B2, it can be seen that the sludge combustor at ANL's Installation is compliant with the ELVs stated in WID.

7. Emissions to Water

There are no emissions to water attributable to the operation of the sludge combustor.

8. Summary of Plant Compliance

Compliance with Permit Conditions

There were no non-compliances of the Environmental Permit BJ7336IL during 2010.

Summary of Enforcement Actions

There were no enforcement actions for the year 2010 associated with the sludge combustor.

9. Summary of Plant Improvements

There were no plant improvements for the year 2010 associated with the sludge combustor.

10. Summary of Information made available to the Public

In furtherance of its objective for social responsibility, Aylesford Newsprint Limited publishes an annual report that summarises its Safety, Health, Environmental and Fire Prevention (SHEF) policy and performance for the previous year. These SHEF reports provide a summary of the following aspects of Aylesford Newsprint's business:

- Environmental Performance,
- Safety Performance
- Operation performance
- Community/ Stakeholder Issues
- Targets for the forthcoming year.

The SHEF report is available from Aylesford Newsprint's website (www.aylesford-newsprint.co.uk)

In addition, as part of its Permit obligations, reports are submitted to the Environment Agency on a regular basis and these reports summarise the emissions to the environment as well operational performance. These reports are held by the Environment Agency.


This report is held by the Environment Agency as well as being available from Aylesford Newsprint's website.

Appendix A

Summary of Sludge Combustor Emissions (Oxides of Nitrogen, Carbon Monoxide, Particulates and TOC)


Sludge Combustor Annual Performance Report 2010

Chart A1 Oxides of Nitrogen (January – June 2010)




Sludge Combustor Annual Performance Report 2010

Chart A2 Oxides of Nitrogen (July – December 2010)




Sludge Combustor Annual Performance Report 2010

Chart A3 Particulates (January – June 2010)




Sludge Combustor Annual Performance Report 2010

Chart A4 Particulates (July – December 2010)




Sludge Combustor Annual Performance Report 2010

Chart A5 Carbon Monoxide (January – June 2010)




Sludge Combustor Annual Performance Report 2010

Chart A6 Carbon Monoxide (July – December 2010)




Sludge Combustor Annual Performance Report 2010

Chart A7 Total Organic Carbon (January – June 2010)



Sludge Combustor Annual Performance Report 2010

Chart A8 Total Organic Carbon (July – December 2010)



Appendix B

Summary of 6-monthly sample Results & Compliance with WID Emission Limit Value (ELVs)

Sludge Combustor Annual Performance Report 2010

Table B1 6-monthly Gaseous Emission Test Results for ANL's Sludge Combustor

Substance	Units	January to June		July to December		Annual Average
		19/04/2010 - 21/04/2010		9/11/2010 - 11/11/2010		
		Actual	Absolute	Actual	Absolute	
VOC's (as TOC)	mg/m3	1.2	1.2	1.30	1.30	1.3
Gaseous chlorides (as HCl)	mg/m3	<0.02	0.02	0.03	0.03	0.03
Gaseous fluorides (as HF)	mg/m3	<0.02	0.02	<0.028	0.03	0.0
Dioxins and furans expressed as TEQ (PCDDs/ PCDFs) (mammals) (ng/m3)	ng/m3	0.002	0.0020	0.0026	0.0026	0.0023
Dioxins and furans expressed as TEQ (PCDDs/ PCDFs) (birds) (ng/m3)	ng/m3	0.004	0.0040	0.0043	0.0043	0.0042
Dioxins and furans expressed as TEQ (PCDDs/ PCDFs) (fish) (ng/m3)	ng/m3	0.002	0.0020	0.0028	0.0028	0.0024
Polychlorinated Aromatic Hydrocarbons (PAHs)	ug/m3	0.05	0.0500	0.29	0.29	0.17
Polychlorinated biphenyls (PCBs) (Human) TEQ	ng/m3	0.0002	0.0002	0.00024	0.00024	0.0002
Polychlorinated biphenyls (PCBs) (Birds) TEQ	ng/m3	0.002	0.0020	0.0011	0.0011	0.0015
Polychlorinated biphenyls (PCBs) (Fish) TEQ	ng/m3	0.00002	0.0000	0.000013	0.000013	0.000017
Cadmium (mg/m3)	mg/m3	0.0006	0.0006	0.0007	0.0007	0.00
Mercury (mg/m3)	mg/m3	0.005	0.0050	0.009	0.009	0.007
Arsenic and compounds (as As)	mg/m3	0.02	0.0200	0.025	0.025	0.02
Lead and compounds (as Pb)	mg/m3	Grouped with Arsenic				As Above
Chromium and compounds (Cr)	mg/m3	Grouped with Arsenic				As Above
Cobalt and compounds (as Co)	mg/m3	Grouped with Arsenic				As Above
Copper and compounds (as Cu)	mg/m3	Grouped with Arsenic				As Above
Manganese and compounds (as Mn)	mg/m3	Grouped with Arsenic				As Above
Vanadium and compounds (as V)	mg/m3	Grouped with Arsenic				As Above
Nickel and compounds (as Ni)	mg/m3	Grouped with Arsenic				As Above
Antimony and compounds (as Sb)	mg/m3	Grouped with Arsenic				As Above
Particulates	mg/m3	0.22	0.22	4.10	4.10	2.16
NO and NO2 expressed as NO2	mg/m3	196	196	214	214	205.0
CO	mg/m3	1.4	1.4	0.28	0.28	0.84
Sulphur dioxide	mg/m3	0.02	0.02	2.40	2.40	1.2

Sludge Combustor Annual Performance Report 2010

Table B2 Comparison of Emissions from ANL's Sludge Combustor and Waste Incineration Directive (WID) Limits

Substance	Units	Annual Average	WID Directive Limits						Compliant
			Daily Average Values (mg/m3)	Half-hourly Average values (mg/m3)		Heavy Metals Average values (mg/m3)		Dioxin Limits ng I-TEQ/Nm3	
				100% Compliance	97% Compliance	30 minutes	8 hours		
VOC's (as TOC)	mg/m3	1.3	10	20	10	-	-	-	Yes
Gaseous chlorides (as HCl)	mg/m3	0.03	10	60	10	-	-	-	Yes
Gaseous fluorides (as HF)	mg/m3	0.0	1	4	2	-	-	-	Yes
Dioxins and furans expressed as TEQ (PCDDs/ PCDFs) (mammals) (ng/m3)	ng/m3	0.0023	-	-	-	-	-	0.1	Yes
Dioxins and furans expressed as TEQ (PCDDs/ PCDFs) (birds) (ng/m3)	ng/m3	0.0042	-	-	-	-	-	0.1	Yes
Dioxins and furans expressed as TEQ (PCDDs/ PCDFs) (fish) (ng/m3)	ng/m3	0.0024	-	-	-	-	-	0.1	Yes
Polychlorinated Aromatic Hydrocarbons (PAHs)	mg/m3	0.17	-	-	-	-	-	-	N/A
Polychlorinated biphenyls (PCBs) (Human) TEQ	ng/m3	0.0002	-	-	-	-	-	Non-Specified	N/A
Polychlorinated biphenyls (PCBs) (Birds) TEQ	ng/m3	0.0015	-	-	-	-	-	Non-Specified	N/A
Polychlorinated biphenyls (PCBs) (Fish) TEQ	ng/m3	0.000017	-	-	-	-	-	Non-Specified	N/A
Cadmium (mg/m3)	mg/m3	0.001	-	-	-	0.05	0.1	-	Yes
Mercury (mg/m3)	mg/m3	0.007	-	-	-	0.05	0.1	-	Yes
Arsenic and compounds (as As)	mg/m3	0.02	-	-	-	0.5	1	-	Yes
Particulates	mg/m3	2.16	10	30	10	-	-	-	Yes
NO and NO2 expressed as NO2	mg/m3	205.0	400	600	400	-	-	-	Yes
CO	mg/m3	0.84	50	100	-	-	-	-	Yes
Sulphur dioxide	mg/m3	1.2	50	-	-	-	-	-	Yes

Appendix C

Reporting of Performance Indicators for the period

1 January 2010 to 31 December 2010

Permit Reference Number: SP3736SJ

Operator: Operator name Aylesford Newsprint Ltd

Installation: Aylesford Paper Mills

Form Number: Agency Form /SP3736SJ/ P11 / 01/11/2005

Reporting of Performance Indicators for the period 1 January 2010 to 31 December 2010

Annual Production/Treatment		
Total Waste Incinerated	99,741	tonnes
Steam Generated	119,602	tonnes

Environmental Performance Indicators

Parameter	Quarterly Average	Units
Natural Gas	34.88	kg/tonne of waste incinerated
Mass of bottom ash produced	13.37	kg/tonne of waste incinerated
Mass of APC residues produced	623.76	kg/tonne of waste incinerated

Trends in Environmental Performance		
Year	Parameter	
	Supplementary Fuel Oil used	Waste Hazard Score
2006	Not Applicable	Awaiting clarification from the Environment Agency as to what is required for this parameter.
2007	Not applicable	

Operator's comments : The sludge combustor operated as intended and described by the PPC Permit (BJ 7336IL/SP3736SJ) associated with this unit.

Signed ...Jenny Harbour.....
 (authorised to sign as representative of Operator)

Date...14/01/2011.....